

To

The Principal,
National Public School,
Village Choudari Wala, Nausherra Pannuan,
Distt. Tarn Taran.

No. 102

Dated: 12/05/2021

Subject: - Building safety certificate for the year (2021 -2026)

Ref: - Your letter 74 Dated: 20-04-2021.

The Sub Divisional Engineer, Provincial Sub Division Patti vide his letter No. 01 Dated 10-05-2021 has reported this office that the building National Public School Village Choudari Wala, Nausherra Pannuan, Taran Taran has been inspected and found the same visually safe and fit for human inhabitation for the year i.e upto 31-03-2026.


DA/Perfoma


Executive Engineer,
Construction Division No.2,
PWD B&R., Amritsar.



Endst.No. _____ Dated: - _____

Copy to the Sub Divisional Engineer, Provincial Sub Division Patti,
W.R.T. his office letter No. 01 Dated 10-05-2021 for information and necessary action.


Executive Engineer,
Construction Division No.2,
PWD B&R., Amritsar.

PROFORMA FOR THE SAFETY OF SCHOOL BUILDING

PART- 1

(To be filled by the Head of School/ Institute)

1.	Name of the School	National Public School
2.	Location	National Public School, Village: Choudhari Wala P.O. Naushera Pannuan Tehsil & District: Tarn Taran-143409.
3.	Plot Area	2 Acres 17 Marlas (8523 Sq. Mts)
4.	Plinth Area	1836.80 Sq. Mts.
5.	Number of Storey's	3
6.	Area of constructed part of building	4197.33 Sq. Mts / 45163.32 sqft
7.	If the building has been constructed under the supervision of a qualified Engineer, the following details may be given	
a)	Name of the Engineer with qualification	
b)	Address of Engineer	
c)	Set of Structural drawings used in the construction, if available	Yes No
d)	Name & address of Architect with qualification	Mr. Amanpreet Singh (B.Arch.) (Choudhary & Associates) 15/31, Mall Road, Amritsar.
8.	Whether the building has been constructed for the purpose	
a)	School	Yes
b)	Residential Purpose and converted for use as a School	No.
9.	Materials used for roofs:	
a)	R.C.C. Slabs/R.B.C. Slabs	Yes
b)	R.S. Joist & Battens	No
c)	Wooden joists & Battens	No
10.	Materials used for walls:	
a)	Mud Mortar	No
b)	Cement Mortar	Yes
c)	Lime Mortar	No

12.	A detailed drawing indicating dimensions of the rooms along with size and location of doors and windows (Attached)	Attached herewith.
13.	For Fire Safety:	
a)	Whether the width of staircase is 1.5 mtr?	Yes.
b)	Whether portable Fire Extinguisher exists?	Yes.
c)	Whether the school is free from inflammable & toxic material?	Yes.
d)	Whether cooking of food is done at a safe place?	Yes.
e)	Whether any Thatch or combustible material has been used?	No.
14.	Requirement of Fire Protection arrangements under NB- Part-IV	
a)	Whether Hose Reel provided?	No.
b)	Whether down comer provided?	No.
c)	Whether Automatic sprinkler provided?	No.
d)	Whether underground static water storage tank of capacity of 5000 Ltr. (if covered area exceeds 1500 Sqm)?	No.
e)	Whether overhead tank of capacity of 10000 Ltr exists (in case of hose reel) 20000 Ltr?	Yes
f)	Whether one electric and one diesel pump of 3 Kg/cum pressure of capacity 1620 LPM, one electric pump of Capacity 180 LPK exists near underground static tank?	No.
g)	Whether a pump of 3 Kg/cum pressure & 450/500 LPM exist near overhead tank?	Yes



President/Principal
National Public School
Naushehra Pannuan (T.T)

**Signature of the Head of
School/Institution.**

PART-II

(To be filled by the Sub Divisional Engineer of P.W.D B&R) Department)

National Public School, Village Choudhari Wala Dih Taran

- a) I have visited the above mentioned school on dated.....27-04-2021..... and have visually inspected it from all angles of safety and find it fit for normal use as School buildings.
- b) In case any addition/ alteration or expansion and modifications to this buildings is to be carried out, the same be carried out under the supervision of a qualified Engineer and this certificate may be reobtained after the completion from the undersigned.
- c) In case the building is affected by food, or if there is settlement of walls/ foundations or sagging of roofs etc. immediate inspection of the undersigned by arranged to check the stability and safety of the building.
- d) This building can be safety occupied for normal use upto (indicate upto which it can be used).....31 March 2026..... [5 years i.e. 2021-22, 2022-23, 2023-24, 2024-25
+ 2025-26]

X
Sub Divisional Engineer,
Provincial Sub Division, PWD
Bukkibatti (Sohi) Taran
PE