

Civil Surgeon Office Tarn Taran

No.CSTT 51

Date: 28/03/23

To Whom It May Concern

This is to certify that we have inspected National Public School , Village Choudhri Wala (Naushehra Pannuan) District, Tarn Taran. After inspecting their Toilets, and other rooms, we can certify that their Cleanliness and sanitation is good. Their water is Potable through RO system as per report of Rural Water Supply and Sanitation Department. This certificate is valid for one year from the date of issue. No Health Hazard is seen in the premises of the school. There are separate washroom for girls and boys.


District Epidemiologist

Tarn Taran


DISTRICT WATER TESTING LABORATORY, TARN TARAN

Village Kaka Kandiala, Block -Tarn Taran District -Tarn Taran.

dwtltt1@gmail.com

To,

**NATIONAL PUBLIC SCHOOL
Naushehra Pannuan**


No.: DWTLTT/2223/00256 Dated : 31/03/2023

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 178 Dated: 27/03/2023

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 29/03/2023. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Tarn Taran

D/A : Test Report



**Authorized Signatory
For, District Water Testing Laboratory, Tarn
Taran**

DISTRICT WATER TESTING LABORATORY, TARN TARAN

Village Kaka Kandiala, Block -Tarn Taran District -Tarn Taran.

dwtltt1@gmail.com



TC-10387

TEST REPORT

| | | | |
|---|--|--------------------------|------------------------------------|
| Name & Address of Customer : NATIONAL PUBLIC SCHOOL Naushehra Pannuan | | Customer Reference No. | No : 178 Dated : 27/03/2023 |
| | | Sample Submitted by | R P Singh |
| | | Date of Sample Receipt | 29/03/2023 |
| | | Analysis Starting Date | 29/03/2023 |
| | | Analysis completion Date | 30/03/2023 |

| | | | |
|--------------------------------------|-------------------------------------|--------------------------|----------------------------------|
| Discipline : Chemical Testing | | Group: Water | |
| ULR No.: | TC103872300000074F | Sample Type : | Water |
| Test Report No.: | DWTLTT/2223/00256 | Date of Issue : | 31/03/2023 |
| Registration no.: | DWTLTT/REG2223/00804 | Condition of Sample : | Unsealed |
| Collection Point: | Private Submersible | Quantity/Type of Bottle: | 1000 ml / Plastic Bottles |
| Scheme/Source: | Not Mentioned(Not Mentioned) | Location/Depth : | NA / 550 ft |
| Village : | Naushehra Pannuan | Habitation : | Naushehra Pannuan |
| Block: | Naushehra Pannuan | District : | Tarn Taran |
| Latitude : | Not Mentioned | Longitude: | Not Mentioned |

| Sr. No | Parameter | Result | As per IS-10500:2012 (2nd Rev.) | | Unit | Reference Method : |
|--------|------------|--------------|---------------------------------|-------------------|------|---|
| | | | Acceptable Limit | Permissible Limit | | |
| 1 | pH | NA | 6.5-8.5 | No Relaxation | -- | IS 3025 (Part 11-1993) Electrometric Method |
| 2 | Colour | 2 | 5 | 15 | CU | IS 3025(Part 4-2021) Visual Comparison Method |
| 3 | Odour | Agreeable | Agreeable | Agreeable | -- | IS 3025 (Part 5 – 2018) (Second Revision) |
| 4 | Taste | Agreeable | Agreeable | Agreeable | -- | IS 3025 (Part 8 – 1984) (RA 2017) |
| 5 | TDS | 575 | 500 | 2000 | mg/l | IS 3025 (Part 16-1984) Gravimetric Method |
| 6 | Turbidity | 0.10 | 1 | 5 | NTU | IS 3025 (Part 10-1984) Nephelometric Method |
| 7 | Alkalinity | 380 | 200 | 600 | mg/l | IS 3025 (Part 23-1986) Indicator Method |
| 8 | Hardness | 300 | 200 | 600 | mg/l | IS 3025 (Part 21- 2019) EDTA Method |
| 9 | Calcium | 28.85 | 75 | 200 | mg/l | IS 3025 (Part 40-1991) EDTA Titrimetric Method |
| 10 | Magnesium | 55.40 | 30 | 100 | mg/l | APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method |
| 11 | Chloride | 63.96 | 250 | 1000 | mg/l | IS 3025 (Part 32-1988) Argentometric Method |

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Mr. Pankaj Kumar
Quality Manager
Authorized Signatory
For, District Water Testing Laboratory, Tarn Taran

----- End of the Test Report -----